

Statement of Eligibility for ECA Claims

Hitachi Air Conditioning Europe SAS confirms the following model combinations meet or exceed the minimum standards detailed in The Energy Technology List: Air Source Heat Pumps and Multi-Split Systems.

≤12kW - EN14825 Minimum Criteria SEER ≥ 6.10; SCOP ≥ 4.00					
Outdoor Unit Model	Indoor Unit Model	Cooling Capacity [kW]	SEER	Heating Capacity [kW]	SCOP
RAC-18WPB	RAK-18RPB	2.0	7.0	2.5	4.3
RAC-25WPB	RAK-25RPB	2.5	7.6	3.4	4.4
RAC-35WPB	RAK-35RPB	3.5	7.2	4.2	4.6
RAC-50WPB	RAK-50RPB	5.0	7.2	6.0	4.4
RAC-25WXB	RAK-25RXB	2.5	8.5	3.2	4.7
RAC-35WXB	RAK-35RXB	3.5	8.5	4.0	4.7
RAC-50WXB	RAK-50RXB	5.0	7.2	5.8	4.5
RAC-18WSB	RAK-18PSB	1.8	7.4	2.3	4.6
RAC-25WSB	RAK-25PSB	2.5	8.5	3.2	4.7
RAC-50WSB	RAK-50PSB	5.0	8.5	4.0	4.7
RAC-25FXB	RAF-25RXB	2.5	6.4	3.4	4.2
RAC-35FXB	RAF-35RXB	3.5	6.4	4.5	4.1
RAS-3HVNC1	RCI-3.0FSN3	7.1	6.1	5.6	4.2
RAS-4HVNC1E	RCI-4.0FSN3	10.0	6.6	8.7	4.5
RAS-4HNC1E	RCI-4.0FSN3	10.0	6.4	8.7	4.5
RAS-2HVNP1	RCI-2.0FSN3	5.0	6.5	5.0	4.7
RAS-2.5HVNP1	RCI-2.5FSN3	5.6	6.1	5.2	4.8
RAS-3HVNP1E	RCI-3.0FSN3	7.1	7.4	6.4	4.4
	RCI-3.0FSN3Ei	7.1	6.6	6.0	4.0
	RCI-3.0FSN3Ek	7.1	6.6	6.0	4.0
RAS-4HVNP1E	RCI-4.0FSN3	10.0	7.9	11.5	4.7
	RCI-4.0FSN3Ei	10.0	7.2	11.5	4.3
	RCI-4.0FSN3Ek	10.0	7.2	11.5	4.3
	RPC-4.0FSN3	10.0	6.5	11.5	4.2
	RPI-4.0FSN4E	10.0	6.5	11.5	4.2
RAS-4HNP1E	RCI-4.0FSN3	10.0	7.7	11.5	4.7
	RCI-4.0FSN3Ei	10.0	7.0	11.5	4.3
	RCI-4.0FSN3Ek	10.0	7.0	11.5	4.3
	RPC-4.0FSN3	10.0	6.4	11.5	4.2
	RPI-4.0FSN4E	10.0	6.3	11.5	4.2

Air Source: Split and Multi-Split (inc.VRF) products became an 'UNLISTED' technology on 7th August 2014. For products purchased after this date, purchasers need to obtain a statement from Hitachi Air Conditioning Europe SAS to confirm that the product meets the eligibility criteria in force at the time of purchase. This statement should then be used as the supporting evidence for the purchaser's ECA claim. Note that the previously listed products will show on the ETL as removed on the 7th August. This does not necessarily mean that the products are no longer eligible for ECA claims – just that they have been removed from the Energy Technology List because the sub-technology category is now unlisted. Purchasers may continue to claim ECA's if the product meets the criteria detailed on the Energy Technology Criteria List, and is certified as such by Hitachi Air Conditioning Europe SAS. For enquiries contact ECAQuestions@carbontrust.co.uk.

For more details of the ETL and ECA scheme, please visit <https://etl.decc.gov.uk/>

Disclaimer: HM Revenue and Customs has the final say on all claims for Enhanced Capital Allowance. The information provided should be used as a guide only.