




# Technical Bulletin



Number	009
Subject	Auto Operation using PC-P2HTE and PC-ART Remote Controller
Date	February 2009

Currently all Utopia and Set Free systems arrive with "Auto" operation disabled. This is because "Auto" is mostly used in the UK due to our wider ambient temperature fluctuations

Please follow these instructions to enable "Auto" operation.

Instruction	Status
<p>1) Ensure Remote Controller is <b>"OFF"</b></p> <p>2) Press <b>"OK"</b> and <b>"RESET"</b> together for more than three seconds</p> 	<p>Service status <b>"01"</b> will appear in bottom window</p> 
<p>3) Press <b>"OK"</b></p> 	<p>Address <b>"00" "00"</b> will show in top window</p> 
<p>4) Press the Temperature Down button once</p> 	<p>Address display in top window will change from <b>"00" "00"</b> to <b>"AA" "AA"</b> (all units)</p>

# Technical Bulletin

<p>5) Press <b>"OK"</b></p>	<p>Indication <b>"B1"</b> will appear in top right window. The <b>"AA"</b> <b>"AA"</b> display will be replaced by <b>"00"</b> status.</p> 
<p>6) Press <b>"SCHEDULE"</b> continuously to scroll through to status <b>"B8"</b></p> 	<p>Indication <b>"B8"</b> will appear in top right window.</p> <p>(<b>"B8"</b> is the Indication for Auto. <b>"00"</b> is the status which is <b>Auto Operation - OFF.</b>)</p> 
<p>7) Press <b>"OK"</b></p>	<p>Status <b>"00"</b> will change to <b>"01"</b>.</p> <p><b>"01"</b> is <b>Auto Operation - On</b></p> 
<p>8) Press <b>"RESET"</b></p> 	<p>Remote controller will return to normal operation mode.</p>
<p>9) Turn remote controller <b>"ON"</b></p>	<p>Normal Operation. (Press <b>MODE</b> button to ensure AUTO is working)</p>