

# Technical Bulletin

Number	067
Subject	Hard Wired Controller for Mitsubishi PKA
Date	21 July 2011

Mitsubishi Electric PKA-RP wall mounted units come supplied with an infra red controller as standard.

To enable hard wired controller an adapter kit is required to connect a terminal block to the indoor unit pcb at connection CN22.

Items required are the CN22 connector and the Terminal Block connector to wire into the CN22 connector.

Part Number	Description	Notes
S71 000 028	CN22 Adapter	Plugs into CN22 on Indoor PCB
S70 515 716	Terminal Block Adapter	Wired into above. Provides terminal block connection for PAR-30 or PAR-21 Controller
PAR-30MAA	Hard Wired Controller	

